Inspection Checklist for bulk transportation Prime mover and trailer (bulk tank, ISO tank) Road tanker (single entity lorry)

* Transport of petroleum and flammable materials in bulk means transport of petroleum and flammable materials in container more than 250 litres water capacity

(A)	Documents Requirements			
1	Manufacturer's report (new application)			
2	Vehicle Log Card (new application)			
3	A copy of prime mover/trailer/tanker photos from front, side, and rear (including			
	licence plate)			
4	A copy of prime mover/trailer/tanker drawing endorsed by PE (new application)			
5	Hydrostatic test or any equivalent test report (once every 5 years) endorsed by			
	local PE			
6	Radiographic test or any equivalent test report (once every 10 years) endorsed by local PE			
7	Certificate of Fire Safety Inspection in accordance with Regulation 5 of the Fire			
	Safety (Petroleum/Flammable Materials) Regulations			
8	Hazardous Materials Transport Driver Permit			
9	ASTRATA Certificate for Annual Inspection for vehicle transporting ≥3 metric			
	tonnes or Tube Trailer.			
(B)	Technical Requirements			
1	Exhaust system in order			
2	Fire shield at rear of cabin provided & in order			
3	Battery cut off			
4	Discharge faucets			
5	Emergency cut off for tanker			
6	Transport Emergency Information Panel (TEIP) according to Singapore Standard			
	586 shall be displayed at the back and both sides of the vehicle			
7	Warning sign "Danger, Highly Flammable" according to Petroleum & Flammable			
	Material Regulations shall be displayed at the back of the vehicle			
8	Bumper (heavy duty steel) 15 cm from tank			
9	Earthing strap touching the ground			
10	Metal conduits for all wirings in good condition			
11	Manhole covers in order			
12	Coaming satisfactory and projected at least 25 mm above manhole covers			
13	Pressure, level & temperature gauges provided			
14	Safety & hydrostatic relief valves provided			
15	Proper battery compartment			
16	Vehicle is equipped with one 9 kg dry powder fire extinguisher and			
	i) 1 x 1 kg dry chemical fire extinguisher, or			
	ii) 1 x 2.3 kg dry carbon dioxide fire extinguisher			

Inspection Checklist for package transportation
Prime mover and trailer (trucking container containing petroleum or Flammable materials in package, examples drums, bottles, pallets etc)

* Transport of petroleum and flammable materials in package means transport of any petroleum or any flammable materials in one or more containers of less than 250 litres water capacity

/A\	Desuments Descripements			
(A)	Documents Requirements			
1	Certificate of Fire Safety Inspection in accordance with Regulation 5 of the Fire			
	Safety (Petroleum/Flammable Materials) Regulations			
2	Vehicle Log Card (new application)			
3	A copy of prime mover / trailer photos from front, side and rear (including licence			
	plate)			
4	Hazardous Materials Transport Driver Permit			
5	ASTRATA Certificate for Annual Inspection for vehicle transporting ≥3 metric			
	tonnes			
(B)	Technical Requirements			
1	Exhaust pipe directed downwards and adequate shrouding (metal cover) to be			
	provided			
2	Fire shield at rear of cabin provided & in order			
3	Battery cut off			
4	Earthing strap touching the ground			
5	Warning placard according to Singapore Standard 586 shall be displayed at the			
	back and both sides of the vehicle			
6	Warning sign "Danger, Highly Flammable" according to Petroleum & Flammable			
	Material Regulations shall be displayed at the back of the vehicle			
7	Earthing strap touching the ground			
8	Metal conduits for all wirings in good condition			
9	Proper battery compartment			
10	Vehicle is equipped with one 9 kg dry powder fire extinguisher and			
	i) 1 x 1 kg dry chemical fire extinguisher, or			
	ii) 1 x 2.3 kg dry carbon dioxide fire extinguisher			

Inspection Checklist for package or bulk transportation Vehicles constructed to carry goods (e.g. lorries, pick-ups)

* Transport of petroleum and flammable materials in package means transport of any petroleum or any flammable materials in one or more containers of less than 250 litres water capacity

^{*} Vehicles used for transport of flammable gases must not have a roof covering.

(A)	Documents Requirements
1	Vehicle Log Card (new application)
2	Certificate of Fire Safety Inspection in accordance with Regulation 5 of the Fire
	Safety (Petroleum/Flammable Materials) Regulations
3	A copy of lorry / pick-up photos from front, side, and rear (including licence plate)
4	Hazardous Materials Transport Driver Permit
5	Supplier's authorization letter (for LPG dealers only)
6	ASTRATA Certificate for Annual Inspection for vehicle transporting ≥3 metric
	tonnes
(B)	Technical Requirements
1	Platform of the vehicle is lined with timber or is timber constructed so as to minimize
	contact between the metal parts of the platform and any container
2	Protective railings lining the platform of the vehicle are at least 1 m in height in order
	to secure any container and to prevent such container from falling off the vehicle
	when the vehicle is in motion
3	Glass at the back of the driver cabin, if any is of wired glass or toughened or safety
	of not less than 6 mm in thickness to act as a fire resisting shield
4	Battery is covered with appropriate insulation material to prevent electrical spark from
	igniting any flammable vapor from any container
5	Exhaust pipe is extended at least 150 mm outwards away from the vehicle tail box
	or is directed downward to keep vehicle exhaust away from any container
6	Warning placard according to Singapore Standard 586 shall be displayed at the front,
_	both sides and the back of the vehicle
7	Warning sign "Danger, Highly Flammable" according to Petroleum & Flammable
	Material Regulations shall be displayed at the back of the vehicle
8	Vehicle is equipped with one 9 kg dry powder fire extinguisher and
	i) 1 x 1 kg dry chemical fire extinguisher, or
	ii) 1 x 2.3 kg dry carbon dioxide fire extinguisher

Inspection Checklist for package transportation Enclosed Vehicles (e.g. Van or box up vehicle)

* Transport of petroleum and flammable materials in package means transport of any petroleum or any flammable materials in one or more containers of less than 250 litres water capacity


(A)	Documents Requirements					
1	Vehicle Log Card (new application)					
2	Certificate of Fire Safety Inspection in accordance with Regulation 5 of the Fire Safety (Petroleum/Flammable Materials) Regulations					
3	A copy of van / box up vehicle photos from front, side, and rear (including licence plate)					
4	Hazardous Materials Transport Driver Permit					
5	ASTRATA Certificate for Annual Inspection for vehicle transporting ≥3 metric tonnes					
(B)	Technical Requirements					
1	Adequate ventilation shall be provided on top and bottom (louvres) and exhaust fan according to Petroleum & Flammable Material Regulations					
2	Platform of the vehicle is lined with timber or is timber constructed so as to minimize contact between the metal parts of the platform and any container					
3	Battery is covered with appropriate insulation material to prevent electrical spark from igniting any flammable vapor from any container					
4	Exhaust pipe is extended at least 150 mm outwards away from the vehicle tail box or is directed downward to keep vehicle exhaust away from any container					
5	Warning placard according to Singapore Standard 586 shall be displayed at the front, both sides and the back of the vehicle					
6	Warning sign "Danger, Highly Flammable" according to Singapore Standard 586 shall be displayed at the back of the vehicle					
7	Vehicle is equipped with one 9 kg dry powder fire extinguisher and					
	 i) 1 x 1 kg dry chemical fire extinguisher, or ii) 1 x 2.3 kg dry carbon dioxide fire extinguisher 					


Annex D

Inspection Checklist for package transportation Vehicles (e.g. van or box up vehicle)


Apart from the opening on top behind the driver's cabin, please see our requirement:

- Only Class 3 FM Liquid/Petroleum & Class 4 Solid are permitted to be transported in a box-up/enclosed vehicle with:
 - Adequate ventilation shall be provided as to prevent the accumulation of any flammable vapors in the vehicle.
 - Spacing between ventilation louvers (top and bottom) shall not exceed 3m horizontally.
 - Exhaust fan to circulate air inside the vehicle.
 - The glass at the back of the driver cabin is of wired glass or toughened or safety glass of not less than 6 millimeters in thickness to act as a fire shield.
- 2 Class O petroleum or any FM GAS Class 2 gas flammable material is not permitted to be transported in a box-up vehicle or vehicle with roof covering whether permanent or otherwise.







SIDE VIEW




TOP VIEW



SIDE VIEW




TOP VIEW



SIDE VIEW



TOP VIEW



SIDE VIEW

Min. 1 Nos. Of Exhaust Fan

TOP VIEW

Vehicle Inspection Checklist E Inspection Checklist for LNG transportation Vehicles (e.g. Prime Mover, Trailer and Road Tanker)

(A)	Documents Requirements			
1	Vehicle Log Card (new application)			
2	Manufacturer's data report (eg. ASME U-Stamp, EN code, etc)			
3	A copy of prime mover/trailer/tanker drawing endorsed by PE			
4	A copy of prime mover/trailer/tanker tracking endorsed by PE A copy of prime mover/trailer/tanker technical calculations for stability endorsed by PE			
	(New Tank)			
5	Certificate of Fire Safety Inspection in accordance with Regulation 5 of the Fire Safety (Petroleum/Flammable Materials) Regulations			
6	A copy of prime mover/trailer/tanker photos from front, side and rear (including licence plate)			
7	Hazardous Materials Transport Driver Permit			
8	Hydrostatic test or any equivalent test report endorse by local PE (New Tank)			
9	Radiographic test or any equivalent test report endorse by local PE (New Tank)			
10	Pneumatic or equivalent test report for tank and manifold piping system (working pressure) endorsed by PE (once every 5 years)			
(B)	Technical Requirements			
1	Prime Mover/ Road Tanker equipped with ABS system			
2	Fire shield at rear of cabin provided and in order			
3	Roll Over Prevention Stability System provided			
4	Exhaust system in order (adequately shielded from direct contact with fuel from overfilled			
	tanks and leaks)			
5	Rear and side under-run protection (heavy duty steel) 15 cm from tank			
6	Metal conduits for all electrical wirings in good condition			
7	Anti-Tow Interlocks systems (to prevent driving away while connected to driving rack or during dispensing) in order			
8	Battery cut off in order / Proper battery compartment			
9	2 x 9 kg dry powder and 1 x 1 kg dry powder / 2.5 kg CO2 fire extinguishers			
10	Transport Emergency Information panel (TEIP) complying with GHS (Warning notices) provided at 3 sides			
11	Earth winch shall be provided for operating during load and unloading of LNG			
12	Spark arrestor (Flame Trap) provided			
13	Earthing strap provided and touching the ground			
14	Visual Inspection on Outer Vessel / Tank (eg. to inspect for any sign on sweating, cold spots or algae)			
15	All vent pipe nozzles are piped upwards and are not piped downwards to the chassis (LNG Trailer/ ISO Tanker)			
16	Discharge Faucets in order			
17	Lighting in cabinets shall be Vapor Proof design or explosion proof design (Intrinsically safe)			
18	Cabinet enclosure shall be designed with louvers			
19	Wiring circuit shall be house in steel conduits			
20	All valves and Safety pressure relief valves in working order			
21	Pressure and Level gauges in working order			
22	Vacuum reading in working order (< 20 micron)			
23	Emergency cut off device in working order			
24	Pump, Vaporizer and piping yearly maintenance report (Renew)			
	· · ··································			

S/N	Chemical	Schedule	Transport Licence Duration and Additional Conditions	Documents and Technical Requirements
1	O-Alkyl (≤C10, including cycloalkyl) N, N- dialkyl (Me, Et, n-Pr or i-Pr) phosphoramidocyanidates	S1A	12 months Licence only	Prime Mover/Trailer (BULK/ISO TANK)/ Road Tanker – To follow Annex A
	E.g. Tabun: O-Ethyl N, N-dimethyl phosphoramidocyanidate		Compulsory ASTRATA report	Prime mover and trailer (trucking
	Sulphur mustards			container containing petroleum or
	(a) 2-Chloroethylchloromethylsulfide		Compulsory	Flammable materials
	(b) Mustard gas: Bis(2-chloroethyl)sulfide		to provide armed escorts	in package, examples drums, bottles, pallets
	(c) Bis(2-chloroethylthio)methane	 	• Compulsory	etc) – To follow Annex B
2	(d) Sesquimustard: 1,2-Bis(2-chloroethylthio)ethane	S1A	at any one time transport not	Vehicles constructed
_	(e) 1,3-Bis(2-chloroethylthio)-n-propane		more than 100	to carry goods (e.g.
	(f) 1,4-Bis(2-chloroethylthio)-n-butane	-	mg	lorries, pick-ups) –
	(g) 1,5-Bis(2-chloroethylthio)-n-pentane	-	• Transport	To follow Annex C
	(h) Bis(2-chloroethylthiomethyl)ether	-	timing, 9 to	Enclosed Vehicles
	(i) O-Mustard: Bis(2- chloroethylthioethyl)ether		5pm only	(e.g. Van or box up vehicle) – To follow Annex D
3	N, N-Dialkyl (Me, Et, n-Pr or i-Pr) phosphoramidic dihalides (>30% purity)	S2B		Prime Mover/Trailer (BULK/ISO TANK)/
4	N,N-Dialkyl (Me, Et, n-Pr or i-Pr) aminoethane-2-ols and corresponding protonated salts (>30% purity)	S2B		Road Tanker – To follow Annex A
5	Pinacolyl alcohol : 3,3-Dimethylbutan-2-ol	S2B		Prime mover and trailer (trucking
6	Trimethyl phosphite	S3B		container containing petroleum or
7	Triethyl phosphite	S3B	• 12 or 24 months subject	Flammable materials in package, examples drums, bottles, pallets
8	Dimethyl phosphite monochloride (>30% purity)	S3B	to 3000L, similar to the rest of PFM requirements	etc) – To follow Annex B
9	Sulfur monochloride (>30% purity)	S3B		Vehicles constructed
10	Sulfur dichloride (>30% purity)	S3B		to carry goods (e.g. lorries, pick-ups) – To follow Annex C
11	Ethyldiethanolamine (>30% purity)	S3B		Enclosed Vehicles
12	Methyldiethanolamine (>30% purity)	S3B		(e.g. Van or box up vehicle) – To follow Annex D

S/no	Inspection Bodies approved to carry inspection on vehicles base on above checklist / approved agent for installation of tracking device, horns and blinkers, orange vehicle number plate	Checklist A	Checklist B	Checklist C	Checklist D	Checklist E	Installation of Tracking Device etc
1	Apave TIV Asia Pte. Ltd. 450 Alexandra Road #04-01 UE Bizhub West, Singapore 119960 Tel: 63298921	yes	yes	•	-	yes	•
2	Bureau Veritas 28 Ayer Rajah Crescent #04-01 Singapore 139959 Tel: 62752886	yes	yes		1	yes	•
3	JIC Inspection Services Pte Ltd 53 Pioneer Road Singapore 628505 Tel: 68639639, Fax: 68631838	yes	yes	yes	yes	•	
4	 STA Inspection Pte Ltd i) 302 Sin Ming Road Singapore 575627 Tel: 64521398, Fax: 64538244 ii) 249 Jalan Boon Lay Singapore 619523 Tel: 6261 6178, Fax: 64538244 		-	yes	yes	-	•

S/no	Inspection Bodies approved to carry inspection on vehicles base on above checklist / approved agent for installation of tracking device, horns and blinkers, orange vehicle number plate	Checklist A	Checklist B	Checklist C	Checklist D	Checklist E	Installation of Tracking Device etc
5	 VICOM LTD i) 385 Sin Ming Drive Singapore 575718		yes	yes	yes		
	 iii) 501 Yishun Industrial Pk A Singapore 768732 Tel: 67559028, Fax: 67559905 iv) 23 Kaki Bukit Ave 4 Singapore 415933 Tel: 67495422, Fax: 67440441 v) 20 Changi North Crescent Singapore 499613 Tel: 65454808, Fax: 65430973 	·	λé	ує	ye		
6	Astrata (Asia Pacific) Pte Ltd Block 750E (Estuary Bldg) Chai Chee Road #05-02 Technopark @ Chai Chee Singapore 469005 Tel +65 63388133 Fax +65 63385373 www.astratagroup.com	1	1	1	1	-	yes

Explanatory notes

Hazardous Materials Transport Driver Permit

Drivers need to attend course and obtain a Hazardous Materials Transport Driver Permit (HTDP). To register for the HTDP course, you can choose one of the following Institutions or accredited bodies.

SCDF ACCREDITED TRAINING INSTITUTIONS (ATIS) HAZARDOUS MATERIALS TRANSPORT DRIVER COURSE (HTDC)

S/N	NAME OF COMPANY
1	ABSOLUTE KINETICS CONSULTANCY PTE LTD 64, HILLVIEW TERRACE SINGAPORE 669277 MR SETHUPATHY SRIBALASUBRAMANIAM TEL: +65 66905571 FAX: +65 67633885 EMAIL: SriBalu.S@SG-AKC.com
2	AAT TRAINING HUB PTE LTD 320 SERANGOON ROAD #11-08 @CENTRIUM SQUARE SINGAPORE 218108 MS FITRI/ MS ROKIAH TEL : +65 62924804 (EXT 807) FAX : +65 67633885 EMAIL: norfitri@aattraininghub.com; admin@aattraininghub.com
3	ADVANTA GLOBAL PTE LTD 20 BENDEMEER ROAD, #04-06 BS BENDEMEER CENTRE, SINGAPORE 339914 (NEW HEAD OFFICE & TRAINING CENTRE) MR SRIVALLI TEL: +65 64171153 / +65 62952112 / +65 81295935 FAX: +65 62956683 EMAIL: srivalli@avanta.com.sg
4	BS TECHNOLOGY PTE LTD 5, TUAS AVENUE 3, BS LOGISTICS HUB SINGAPORE 639405 MR SRIRAM / MR HANSEN NG TEL : +65 64162691 / +65 64162694 FAX : +65 62659717 EMAIL: sriram@bokseng-ipl.com; hansen.ng@bokseng-ipl.com

S/N	NAME OF COMPANY
5	COSEM SAFETY AND SECURITY SERVICES PTE LTD 37, GUL AVENUE SINGAPORE 629677 MS FARHANA / MS FARIDAH
	TEL : +65 68984171 (x 113) / +65 68984171 (x 112) FAX : +65 68982428 EMAIL: farhanah@cosem.org.sg; training@cosem.org.sg; faridah@cosem.org.sg
6	HAZMAT TRAINING 146A, CHANGI ROAD SINGAPORE 419726 MS NG BEE HONG
	TEL : +65 65425539 FAX : +65 65425296 H/P : +65 96755796 EMAIL: beehong@haz-mat-training.com
7	NTUC LEARNING HUB e2i (DEVAN NAIR INSTITUTE FOR EMPLOYMENT AND EMPLOYABILITY) 80 JUROG EAST STREET 21, #02-03, SINGAPORE 609607 MS SERENE ONG/MS JEFEI TAN/ MS NURUL HANISAH
	TEL: +65 6705 4097 EMAIL: FTSME@ntuclearninghub.com;
8	PIONEER TRAINING CENTRE PTE LTD 1, SOON LEE STREET #03-49/50, PIONEER CENTRE SINGAPORE 627605 MS WINNIE LAU
	TEL: +65 63163290 FAX: +65 63163265 H/P: +65 8338332 EMAIL: pioneertrainingcentre2010@gmail.com; centremanager@pioneertrainingcentre.com; winnielau@pioneertrainingcentre.com
9	PSA INSTITUTE, PSA CORPORATION LIMITED PSA VISTA, #06-01, PSA HORIZONS 1 HARBOUR DRIVE SINGAPORE 117352 MS ANGELA LOO/ MR LIONG KWOK YEAN/ MR CHAN WEI KIAT
	TEL: +65 6279 4460 FAX: +65 67717316 EMAIL: ANGELAL@globalpsa.com; kyliong@globalpsa.com; cweikiat@globalpsa.com

S/N	NAME OF COMPANY
10	TECS FIRE AND SAFETY SERVICES 20, TOH GUAN ROAD CJ LOGISTICS BUILDING #07-02 SINGAPORE 608839 MS NORDAYANA /MS RAHAINA
	TEL: +65 63621886 FAX: +65 63623973 H/P: +65 83839195 EMAIL: admin3@tecs-firensafety.com.sg; am@tecs-firensafety.com.sg; tm@tecs-firensafety.com.sg; admin1@tecs-firensafety.com.sg
11	UBTS ACADEMY PTE LTD 821, BUKIT BATOK WEST AVENUE 5 SINGAPORE 659087 MR JUKIT/ MS LILY CHEW / MS SIEW LEE
	TEL : +65 64256787 FAX : +65 62508218 H/P : +65 97479922 EMAIL: training@ubts.academy; lilychew@ubts.academy; siewlee@ubts.academy
12	LIFESKILLS ACADEMY (BIZNESS & MEDIA RESOURCES PTE LTD) 18 BOON LAY WAY #09-144 TRADEHUB21 SINGAPORE 609966 MR JOSEPH HONG / MS SALLY HONG
	TEL: +65 68160492 H/P: +65 83337118 / +65 88112861 EMAIL: joehong@bizmediaresources.com.sg; business@lifeskillsacademy.edu.sg
13	REALSAFE TRAINING CENTRE 273 CHANGI ROAD, SINGAPORE 419754 MR ANUAR BIN ABDUL MAJID
14	H/P : +65 81684401; +65 81684403 EMAIL: anuar_adesc@adrealsafe.com; aqilahma_rtc@adrealsafe.com;
14	WONG FONG ACADEMY PTE LTD 79 JOO KOON CIRCLE #03-03 SINGAPORE 629107 MS LIYANA/MS RINA/ MS JANIFAR
	TEL : +65 68633686 H/P : +65 88213190 EMAIL: sales@wfa.edu.sg

S/N	NAME OF COMPANY						
15	EVERSAFE ACADEMY PTE LTD 2 KAMPONG KAPOR ROAD SINGAPORE 208674						
	MS APARNA/MS VANISHREE						
	TEL : +65 62978417 (EXT 708) ; +65 62978417 (EXT 759) H/P : +65 94566715 EMAIL: sales@eversafe.com.sq; diploma2@eversafe.com.sq;						
16	SAAA CARGO SERVICES PTE LTD 2 KALLANG AVENUE #08-03 CT HUB SINGAPORE 339407						
	MS PAULINE TOK/ MS LINDA TEL : +65 65455006 H/P : +65 98636863 EMAIL: admin@saaa.org.sg; finance@saaa.org.sg						
17	GREENSAFE INTERNATIONAL PTE LTD 175A BENCOOLEN STREET #08-11, BURLINGTON SQUARE SINGAPORE 189650						
	MR VICTOR JAMES EDWARD						
	TEL : +65 62970388 H/P : +65 90695122 EMAIL : victor@greensafe.com.sg						

Transport Emergency Response Plan (TERP)

As part of our continual effort to create a pro-enterprise environment, SCDF has reviewed the Emergency Response Plan (ERP) online submission process. To simplify the online application process, the TERP shall be submitted as part of the Flammable Material Transportation Licence application with effect from 1st August 2017.

Please submit the TERP document together with other supporting documents through <u>goBusiness</u>. Following the implementation of this initiative, TERP applications (New and Renew) in the SCDF Eservices will be closed. TERP Update application will be retained in the SCDF website for you to update the P&FM products.

For clarification on TERP, applicant can call SCDF Transport Risk Branch, Hazmat Department (Attn: SSG Azali at 68481440) or e-mail to Md_Azali_Hussin@scdf.gov.sg

Tracking Device

PI note that vehicle transporting 3 metric tonnes (net wt) or more of petroleum or flammable materials or hydrogen, silane & CNG in tubes (regardless of quantity) will need to install with a tracking devices, immobilizer, horns and blinkers and an orange colour vehicle number plate. PI note that the 3 metric tonnes refer to 3000 kg or 3000 litres, in the nature physical state of the regulated chemical (i.e. the litres for petroleum and liquid FM; the kg for LPG, gaseous FM and solid FM. The vehicle owner can liaise with the agent directly for the installation of the tracking devices.

Vehicles installed with tracking devices are to adhere strictly to approved routes and transportation hours. For details, please visit SCDF website (look for the updated circular on requirements for transportation of Petroleum and flammable materials).

Foreign vehicles transporting 3 metric tonnes (net wt) or more of petroleum or flammable materials or hydrogen, silane & CNG in tubes (regardless of quantity) will also need to comply with the above requirements, otherwise the vehicle will be turned back at the checkpoint with effect from end March 08.

For further details on transport of petroleum and flammable materials, please visit www.scdf.gov.sq

Last Updated: 11 June 2025