



Our Ref: SCDF/HAZ/SRB/05



To MCSTs / Club Houses/ Country Clubs / Associations / Chalet Resorts

Dear Sir / Madam,

Date: 16th Nov 2023

ADVISORY ON THE USE OF LIQUEFIED PETROLEUM GAS (LPG) FOR BARBECUE (BBQ) PITS AT COMMUNAL AREAS

On 16 July 2023, SCDF responded to a fire involving LPG cylinders used at a BBQ pit, which resulted in burn injuries for a member of public. This advisory serve to remind premises owner/operator that the use of LPG cylinders at BBQ pits is not permitted under the Fire Code. This is to minimise fire risks to BBQ pit users and members of public in the vicinity, in the event of an LPG leak and accidental ignition. Safer alternate solutions such as electric grills, charcoal or wood pellets should be considered.

- 2. Please convey the contents of this advisory to members of your Association/Board/Management.
- 3. For any enquiry or clarification, please contact Ms Richall Loh (email: Loh_Han_Lee@scdf.gov.sg or telephone no: 6848 1735). Thank you.

Yours faithfully, (transmitted via email) Koh Wen Xi for COMMISSIONER SINGAPORE CIVIL DEFENCE FORCE









